

Tabela regulacyjna

Sieć o parametrach 90 /70 C

Temperatura zewnętrzna	Temperatura zasilania	Temperatura powrotu
te	tz	tp
-20	90	70
-19	89	69
-18	87	68
-17	86	67
-16	84	67
-15	83	66
-14	82	65
-13	80	64
-12	79	63
-11	77	62
-10	76	61
-9	74	60
-8	73	59
-7	71	59
-6	70	58
-5	68	56
-4	67	55
-3	65	54
-2	64	53
-1	62	52
0	61	51
1	59	50
2	57	49
3	56	48
4	54	47
5	52	46
6	51	44
7	49	43
8	47	42
9	45	41
10	44	39
11	41	38
12	38	37