

**Tabela regulacji temperatury WP
Sieć co o parametrach 130/70°C
węzły cieplne zasilane z kotłowni "Julian"**

temperatura [°C]		
zewnątrzna	zasilania	powrotu
-20	130	70
-19	128	69
-18	125	68
-17	123	67
-16	121	67
-15	118	66
-14	116	65
-13	113	64
-12	111	63
-11	108	62
-10	106	61
-9	104	60
-8	101	59
-7	99	58
-6	96	57
-5	94	56
-4	91	55
-3	89	54
-2	86	53
-1	84	52
0	81	51
1	78	50
2	76	49
3	73	48
4	70	46
5	68	45
6	65	44
7	62	43
8	60	42
9	57	40
10	54	39
11	51	38
12	48	36